

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7315-0028:190 Page 1 of 1

CATEGORY: Power Units

LISTEE: Notifier, One Fire-Lite Place, Northford, CT 06472-1653
Contact: Lawrence Flood (203) 484-1200 Fax (203) 484-7309

DESIGN: Model APS-6R Auxiliary power supply. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120/240 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation, electrical rating and UL label.

APPROVAL: Listed as auxiliary power supply for use with separately listed electrically and functionally compatible fire alarm control units.

12-02-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 6, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager